

**TAMPA-HILLSBOROUGH COUNTY
EXPRESSWAY AUTHORITY**

Letter of Clarification No. 2

FOR

INVITATION TO BID

**CONSTRUCTION SERVICES
HYDE PARK AT MORRISON STREET**

ITB O-01519

Letter of Clarification No. 2 ~ ITB No. O-01519

Date of Letter of Clarification: October 23, 2019

To all prospective respondents:

The following responds to questions received on the solicitation reference above:

Question 1:	Regarding plan sheet C-5, there is a callout stating "Contractor To Apply Anti-Graffiti Coating to Bridge Abutment Wall approximately 130 LF in length, Full height of Wall". The existing wall approximates 16 VF in height. There are beam supports and diaphragm concrete infills that extend above the 16 VF height. There is separate wall in between the two bridges that extends above the existing 16VF wall. <u>Please confirm if</u> the concrete walls, beam supports and the diaphragms in between the beams above 16 VF, are to be painted.
Response 1:	All walls facing Morrison Avenue shall receive the anti-graffiti coating, including the beam supports and the wall in the median between the bridges to the top. The diaphragms in between the beams shall not receive the coating.
Question 2:	There are no <u>color</u> callouts for the coating. Does THEA have a preference on this project?
Response 2:	We would recommend the same color as used at Bay to Bay and Swann.

Bidders MUST acknowledge receipt of this Letter of Clarification by signing, dating and returning the completed Acknowledgement of Receipt of Letter of Clarification/Addendum form with Respondent's proposal.

All other items, conditions, and specifications in the procurement document not specifically changed by the Addendum remain unchanged.

Please send all questions to THEA's Procurement Manager, Man Le, via email at Man.Le@tampa-xway.com.