

Questions – 5/16/2023:

1. Reference: Q/A Posted 4.27.23 – Will CSX allow MSE walls at distances greater than 25' from the centerline of track if the wall is not located on CSX property? Please clarify the height of wall includes top of sound wall; therefore MSE walls with a height from finished grade to top of sound wall greater than the distance from front face of wall to CSX ROW will not be allowed.

Answer: As previously responded to below on question #21 received by THEA on 4/19/21, CSX is concerned that the catastrophic failure of the MSE wall could end up on CSX property and impact their operations. No further details were received from CSX, but they are concerned with the entire MSE wall, including the sound wall on top of it.

21. Will CSX allow MSE walls at distances greater than 25' from the centerline of track if the wall is not located on CSX property?

Answer: That depends on several factors such as the height of the wall and whether CSX determines if there was a wall failure if it would fall on their ROW. The selected Design-Build Firm will have to submit their design to CSX for approval and construction permits.

www.tampa-xway.com/wp-content/uploads/2023/05/O-0622-South-Selmon-Capacity-Question-and-Answers-4.19.23.pdf