

THIS FORM IS INTENDED TO FACILITATE AND GUIDE THE DIALOGUE DURING A PRE-APPLICATION MEETING BY PROVIDING A PARTIAL "PROMPT LIST" OF DISCUSSION SUBJECTS. IT IS NOT A LIST OF REQUIREMENTS FOR SUBMITTAL BY THE APPLICANT.



**SOUTHWEST FLORIDA WATER MANAGEMENT DISTRICT
RESOURCE REGULATION DIVISION
PRE-APPLICATION MEETING NOTES**

**FILE
NUMBER:

PA 405560**

| | | | |
|----------------------------|-------------------------------------------------|-------------------------|--------------|
| Date: | 04/17/2018 | | |
| Time: | 10:00 | | |
| Project Name: | Twiggs Street Improvements Design-Build Project | | |
| District Engineer: | Rob McDaniel, Buddy Wood | | |
| District ES: | None | | |
| Attendees: | Al Stewart (HNTB) | | |
| County: | Hillsborough | Sec/Twp/Rge: | 18, 19/29/19 |
| Total Land Acreage: | 1.5 acres | Project Acreage: | 1.5 acres |

Prior On-Site/Off-Site Permit Activity:

- No permitting history for this segment of Twiggs Street.

Project Overview:

- This project involves widening existing four-lane Twiggs St. 6; to the north and south between Meridian and Nebraska Avenues to add a westbound right turn lane onto Nebraska Ave. The project length is approximately 632 feet along Twiggs St and the area of work is approximately 1.5 acres.

Environmental Discussion: (Wetlands On-Site, Wetlands on Adjacent Properties, Delineation, T&E species, Easements, Drawdown Issues, Setbacks, Justification, Elimination/Reduction, Permanent/Temporary Impacts, Secondary and Cumulative Impacts, Mitigation Options, SHWL, Upland Habitats, Site Visit, etc.)

- N/A

Site Information Discussion: (SHW Levels, Floodplain, Tailwater Conditions, Adjacent Off-Site Contributing Sources, Receiving Waterbody, etc.)

- Road widening on both sides of Twiggs Street to accommodate a new turn lane. The turn lane will be less than 0.25 mile in length, meeting the exemption criteria.

Water Quantity Discussions: (Basin Description, Storm Event, Pre/Post Volume, Pre/Post Discharge, etc.)

- Formal water quantity attenuation is not required for the new turn lane.
- There will no fill placement within the riverine flood plain.

Water Quality Discussions: (Type of Treatment, Technical Characteristics, Non-presumptive Alternatives, etc.)

- Formal water quality treatment is not required for the new turn lane.

Sovereign Lands Discussion: (Determining Location, Correct Form of Authorization, Content of Application, Assessment of Fees, Coordination with FDEP)

- N/A

Operation and Maintenance/Legal Information: (Ownership or Perpetual Control, O&M Entity, O&M Instructions, Homeowner Association Documents, Coastal Zone requirements, etc.)

-

Application Type and Fee Required:

- Request for Verification of Exempt Activities - \$100 fee.
- Provide a plan drawing showing the new turn lane will be less than 0.25 mile in length.

Other: (Future Pre-Application Meetings, Fast Track, Submittal Date, Construction Start Date, Required District Permits – WUP, WOD, Well Construction, etc.)

- Provide soil erosion and sediment control measures for use during construction. Refer to ERP Applicant's Handbook Vol. 1 Part IV Erosion and Sediment Control.

Disclaimer: The District ERP pre-application meeting process is a service made available to the public to assist interested parties in preparing for submittal of a permit application. Information shared at pre-application meetings is superseded by the actual permit application submittal. District permit decisions are based upon information submitted during the application process and Rules in effect at the time the application is complete.