DRAWING ACCURACY WAS NOT VERIFIED. FIELD VERIFY LOCATIONS AND DEPTHS.

NORTH

SEC.18,19--T28S--R19E
SCALE 1"=40'

REMOVE 240' OF 30"WM

F&I: 240' OF 30"WM

REMOVE 6" DDCV

F&I: 12" PLUG

F&I: 30" SOLID SLEEVE
CONNECT TO EXISTING
SAMPLE TAP LOCATION

F&I: 12"X6" TAPPING SLEEVE
F&I: 6" TAPPING VALVE W/BOX
30' OF 6" DIP WATER MAIN
6" DDCV ASSEMBLY
8'4"X5'8" VAULT
6" GATE GATE VALVE W/BOX
6" PLUG

F&I: 12"X12" TAPPING SLEEVE
12" TAPPING VALVE W/BOX
12" 90° BEND
75' OF 12" DIP WM
12" SOLID SLEEVE
RESTRAIN ALL JOINTS
SAMPLE TAP LOCATION

F&I: 30"X12" TEE
30" 45° BEND

30" 45° BEND
30" BFV W/BOX

TWIGGS STREET

MERIDIAN AVE.

F&I RESTRAIN JOINT NOTES:

1. F&I RESTRAIN JOINT 30" DIP FROM CONNECTION TO 151' N. OF 90° BENDS.

CHRIS BARQUIN, P.E.
CITY OF TAMPA WATER DEPT.
306 E. JACKSON ST., 5E
TAMPA, FL 33602
P.E. #31900

30" WM ON MERIDIAN AVE.	CHRIS BARQUIN FLA. P.E. # 31900	No. Date REVISION By Approved Date	Des: JRD Dwn: JDM Ckd: GE	W.O. 6822 File: SELMON XTOWN FILE NUMBER FC84-139B	SHEET TWD 5 OF TWD 18 SHEETS